

NOTES:

1. BONDING /GROUNDING DETAIL FOR USE WITH SCH. 40 PVC CONDUIT AND PULL BOX WITHIN 10' FROM POLE.
2. THE GROUND ROD SHALL BE INSTALLED AT AN OBLIQUE ANGLE NOT TO EXCEED 45 DEGREES FROM THE VERTICAL.
3. POLE STANDARD TYPE 1B AND FOUNDATION REQUIREMENTS SHALL CONFORM TO SECTION 86-2.04 OF THE STATE SPECIFICATIONS AND STATE STANDARD PLAN DETAILS (LATEST ENFORCED ISSUE).

APPROVED BY


*AWJ*

DATE

3/3/92

POLE TYPE 1B BONDING - METHOD A

DEPARTMENT OF PUBLIC WORKS



DRAWING NO.

E-49